



## **LAMPIRAN**

## Lampiran 1. Data Sheet Fuel Gas Scrubber

Data Sheet for Unfired Pressure Vessels							
Equipment Name: Fuel Gas Scrubber				Location: Arabian Gulf			
Tag No.: 603-36V-01				Plant Location: PS-3K			
No. of Units: 1				Manufacturer/Model:			
DESIGN DATA							
1	Orientation	Vertical		CONSTRUCTION MATERIAL			
2	Contents	HC, H <sub>2</sub> S, CO <sub>2</sub>		Part	Material Specification		
3	Criticality Rating	2		Shell	SA516Gr.60 (see note 4, 5)		
4	Service	Lethal, Sour		Cladding/Lining of shell	-		
5	Design Code	ASME Sec. VIII DIV. 1		Heads	SA516Gr.60 (see note 4, 5)		
6	Code Stamp	Yes		Cladding/Lining of heads	-		
7				Supp. Skirt (Top/Bottom Sec.)	SA516Gr.60/SA283GR.C (note 4, 5)		
8	Temperature			Reinforcing pads	-		
9	Design - Upper/Lower	°C	120/4	Self Reinforcing Nozzles	SA105		
10	Operating - Max./Normal / Min.	°C	65/ - /59	Nozzle neck (pipes)	SA106Gr.B (note 4, 5)		
11	Pressure			Forged Flanges	SA 105 (note 4, 5)		
12	Design (Internal)	barg	40	Internal Flanges	-		
13	Design External	barg	Full Vacuum	Welding elbow	SA 234 WPB		
14	Operating - Max./Norm/Min	barg	- / 34 / -	Demister	Solution treated SS316L		
15	Corrosion Allowance	mm	3	Baffles	-		
16	Specific Gravity Liquid(HC/W)	Refer Sheet 2		Distributor pipes	-		
17	Gross Capacity	m <sup>3</sup>	6	Base ring/Gusset plate	SA 283 GR C		
18	Vessel Dia (ID)	mm	1300	Vacuum stiffener rings	-		
19	Vessel Length (T/L TO T/L)	mm	4000	Vortex breakers	-		
20	Shop Hydrotest Pressure (N&C)	Per code		Saddles	-		
21	Wind	BS CP3, Chapter V, PART 4		Internal attachments	SA516 Gr.60 (note 4, 5)		
22	Design Wind Speed	m/s	45	External attachments	SA 283 GR C		
23	Seismic	See note 7		External Bolts	SA 193 GR B7( note 2)		
24	Shell Thickness (NOM)	mm	30 VTC	Nuts	SA 194 GR 2H (note 2)		
25	Min. Head Thickness (Top/Bot)	mm	29/29 VTC	Gaskets External	Spiral Wound (note 1)		
26	Skirt Thickness/Height	mm	8/1500	Gaskets Internal	-		
27	Weld Joint Efficiencies:			Internal Bolts	SS 316		
28	Shell	1.0		Nuts	SS 316		
29	Head	1.0					
30	Inspection and Testing						
31	Third Party Inspection	Yes		CONSTRUCTION			
32	Non Destructive Testing:			Type of Heads	2:1 Ellipsoidal		
33	Radiography	100%		Type of support	Skirt Supported		
34	Ultrasonic	Yes, per Code/Specn.		Platform/Ladder/Pipe Clip	Required		
35	Magnetic Particle	100%		Insulation supports	Required		
36	Dye Penetrant	Per Code/Spec		Man way Davit	Required		
37	Post Weld Heat Treatment	Yes		Earthing Boss	Required		
38	Material Impact Test Required	Per code/spec		Lifting Lugs/Eyes/Trunions	Required		
39	Certified Elevated Temp. Test Required	No		Name plate	Required, SS316		
40	Insulation (By others)	mm	No	ESTIMATED WEIGHTS			
41	Fireproofing	mm	No	Empty	Kg	5,700 VTC	
42	Painting (External)	ES-Q-12		Shipping	Kg	VTA	
43	Painting (Internal)	No		Operating	Kg	7,800 VTC	
44				Field Test	Kg	12,900 VTC	
45	NOTES:						
46	1. Gaskets shall be SS316L spiral wound graphite filled with SS316L internal and external rings. Gaskets shall be as per API-60						
47	2. External bolting shall be hot dip galvanised as per BS 729 (BS EN ISO 1461:1999).						
48	3. Indicated thickness of shell, head and skirt are minimum and vendor to confirm the thicknesses.						
49	4. Vessel shall meet all the requirements of NACE MR 0175 and the material shall be HIC tested as per NACE TM 0284.						
50	5. Material for shell and heads shall be of normalised steel, vacuum degassed and secondary calcium treated during manufacture						
51	sulphur content and CE shall not be more than 0.16%, 0.003% and 0.41% respectively.						
52	6. Nozzles shall be self reinforced (Integrally Reinforced) type wherever reinforcement required.						
53	7. Refer Environmental data:1535-0-56-0001.						
54	VTC: Vendor to confirm, VTA: Vendor to advise.						
1	26-Jul-01	APPROVED FOR DETAILED DESIGN		NVR	GMP	GMP	IDB
0	24-06-2001	ISSUED FOR COMMENTS		NVR	GMP	CPS	IDB
REV	DATE	ISSUE DESCRIPTION		ORIG	CHKD	APPRD.	PROJECT CLIENT APPR.
		Worley				Qatar Petroleum	
				Qatar Petroleum			
				Bul Hanine Arab "C" Gas Cap Recycling			
				Project No: 022/00705			Rev.
				Document No: 00705-MEC-DTS-146			1


## Data Sheet for Unfired Pressure Vessel

<b>Equipment Name :</b> Fuel Gas Scrubber		<b>Location:</b> Arabian Gulf					
<b>Tag No. :</b> 603-36V-01		<b>Plant Location :</b> PS-3K					
<b>No. of Units :</b> 1		<b>Manufacturer/Model :</b>					
<b>DESIGN DATA</b>							
1							
2	<b>Process Guarantees</b>						
3	Max liquid in Gas outlet shall not exceed 0.1 Us gal/MMSCF						
4	Max Liquid particle size 20 micron.						
5							
6							
7							
8							
9							
10							
11							
<b>PROCESS DATA</b>							
12							
13	<b>Fluid Name</b>						
14	Case	Uw ainat Gas	Arab A/B				
15	Vapour Flow rate	m3/h	364 351				
16	Vapour Density @ Oper. T/P	kg/m3	28.12 26.77				
17	Vapour Viscosity @ Oper. T/P	cP	0.013 0.014				
18	Molecular Weight		20.7 20.1				
19	Liquid HC Flow Rate	m3/h	- -				
20	Liquid HC Density @ Oper. T/P	kg/m3	628 619				
21	Liquid HC Viscosity @ Oper. T/P	cP	0.24 0.24				
22	Liquid HC Surface Tension	dyne/cm	13.5 13.3				
23	Slug Holding Liquid Volume	m3	- -				
24	Water Flow Rate	m3/h	- -				
25	Water Density @ Oper. T/P	kg/m3	- -				
26	Water Viscosity @ Oper. T/P	cP	- -				
27	Design Margin on Flow Rates	%	10 10				
28	Corrosive Compounds	H <sub>2</sub> S, CO <sub>2</sub>					
29	<b>VESSEL INTERNALS</b>						
30	Gas Demister/Vane Pack	Gas Demister					
31	Vortex Breakers						
32	<b>NOZZLE SCHEDULE</b>						
33	Mark No	Size	Qty.	Flange	Service	Standout (mm)	Reinf Pad (mm)
34		NPS	Nos.	Rating Type/Face		Ext Int	Thick Diam
35	N1	6"	1	300# SR/RF	Fluid Inlet		
36	N2	4"	1	300# SR/RF	Vapour Outlet		
37	N3	3"	1	300# SR/RF	Drain		
38	N4	4"	1	300# WN/RF	PSV		
39	N5	2"	1	300# WN/RF	Vent		
40	N6	2"	1	300# WN/RF	Utility Connection		
41							
42	K1A/B	2"	2	300# WN/RF	Level Indicator		
43	K2A/B	2"	2	300# WN/RF	Level Indicator		
44	K3	2"	1	300# WN/RF	Pressure Indicator/Transmitter		
45	K4	2"	1	300# WN/RF	Pressure Indicator/Transmitter		
46	K5	2"	1	300# WN/RF	Temperature Indicator/Transmitter		
47							
48	M1	20"	1	300# SR/RF	Manway		
49							
50	S <sub>A</sub>	ID.610	1	- -	Skirt Access		
51	S <sub>V</sub>	2"	4	- -	Skirt Vent		
52	S <sub>S</sub>	6"	1	- -	Skirt Sleeve		
53	<b>REMARKS</b>						
54	1. Nozzle sizes and elevations shall be confirmed during detailed engineering.						
55	2. SR RF - Self Reinforced (Integrally Reinforced) nozzle with Raised Face Flange.						
56	3. Vendor to provide details of gas demister.						
57							
<b>Worley</b>		<b>قطر للبترول</b> Qatar Petroleum		<b>Qatar Petroleum</b> Bul Hanine Arab "C" Gas Cap Recycling			
				Project No: 022/00705		Rev: 1	
				Document No: 00705-MEC-DTS-146			

## Data Sheet for Unfired Pressure Vessel

<b>Equipment Name :</b> Fuel Gas Scrubber	<b>Location:</b> Arabian Gulf
<b>Tag No. :</b> 603-36V-01	<b>Plant Location :</b> PS-3K
<b>No. of Units :</b> 1	<b>Manufacturer/Model :</b>

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55



LIQUID LEVELS		mm	HC LIQUID
LAHH	mm	1000	
LAH	mm	750	
NLL	mm	600	
LAL	mm	450	
LALL	mm	300	




**Worley**



**Qatar Petroleum**

<b>Bul Hanine Arab "C" Gas Cap Recycling</b>	
<b>Project No:</b> 022/00705	<b>Rev:</b>
<b>Document No:</b> 00705-MEC-DTS-146	<b>1</b>

## Lampiran 2. Hasil Perancangan PV Elite 2014



## Attachment *nozzle* menggunakan reinforcement pad

**Nozzle Input/Analysis: [N1]**  
 Local Stress Analysis [WRC 107, 297 or Annex G]

**Nozzle Attachment**  
 Insert Nozzle with Reinforcing Pad  
 FVC Catalogue ...  
 Coupling Lookup ...  
 Just Like ...

Existing Nozzle Description :

Nozzle Material : SA-105   
 Schedule | Diameter : 80 | 6 in.  
 Dia. Basis | Thickness Basis : ID | Nominal  
 Total CA. | Actual Thk. : 0.11811 | 0.432 in.

Is this Nozzle Connected to another Nozzle?   
 Parent Nozzle :   
 Distance from 'From' Node | Elev : 5.57742 | 5.57742 ft.

Layout Angle : 180 deg.  
 Radial Nozzle  
 Angled or Lateral Nozzle  
 Centerline Tilt Angle : 0 deg.  
 Cyl./Cone Offset Dimension L : 0 in.

Projection Outside | Inside : 10 | 0 in.  
 Limits [ Diameter | Thickness ] : 0 | 0 in.  
 Overriding Weight : 80.4848 lbm

**Pad or Hub Properties**  
 Pad Material : SA-516 60   
 Pad Diameter / Width : 10.625 | 2 in.  
 Pad Thickness : 0.75 in.  
 Groove Weld Depth : 0.75 in.  
 Weld Leg at Pad OD : 0.625 | 0.530 in.  
 For VIII-1 split pads, multiply A5 by 0.75 per UG-37(h) :

**Additional Weld Data**  
 Nozzle to Pad Fillet Weld Leg : 0.375 | 0.311 in.  
 Nozzle to Shell Inside Fillet Weld Leg : 0 in.  
 Nozzle to Shell Groove Weld Depth : 0.9375 in.  
 ASME VIII-1 Weld Type : None


**Miscellaneous**  
 Flange Material : SA-105   
 Flange Class | Grade : 300 | GR 1.1  
 Flange Type : Weld Neck  
 Neglect Areas : None  
 Tapped Hole Area Loss : 1.8 sq.in.  
 Nozzle Eff. | Shell Eff. : 1 | 1  
 Local Shell Thk. | User Tr : 0 | 0 in.  
 Blind Attached?  Manway/Acs Ope ?

Fatigue Calc ?  Shell Fatigue Curve: Table 3.F.1

A1: 3.284 A2: 0.887 A3: 0.000 A4: 0.473 A5: 2.003 Aav.: 6.646 Ar: 2.615 [Passed]


Noz:[1 of 9]

Flange Rating: 668,000 psig




Universitas Muhammadiyah Yogyakarta	Skala 1:30	Digambar: Gurun Wisnu Permadi	Peringatan
	Satuan mm	Diperiksa:	
	Tanggal: 30 Desember 2017	Dilihat:	
	Fuel Gas Scrubber		No. 1
			A4

### Lampiran 3. Menentukan Faktor A






### Lampiran 4. Menentukan Faktor B pada Shell



## Lampiran 5. Menentukan Faktor B pada Head



Lampiran 6. Tebal Dinding *Head* dan *Shell*

## Tebal Dinding Shell & Head

Ukuran Tebal Dinding Shell & Head Standar :

- 1/4 = 0,25	- 7/8 = 0,875	- 1-1/2 = 1,5
- 5/16 = 0,3125	- 15/16 = 0,9375	- 1-9/16 = 1,5625
- 3/8 = 0,375	- 1 = 1,0	- 1-5/8 = 1,625
- 7/16 = 0,4375	- 1-1/16 = 1,0625	- 1-11/16 = 0,6875
- 1/2 = 0,5	- 1-1/8 = 1,125	- 1-3/4 = 1,75
- 9/16 = 0,5625	- 1-3/16 = 1,1875	- 1-13/16 = 1,8125
- 5/8 = 0,625	- 1-1/4 = 1,25	- 1-7/8 = 1,875
- 11/16 = 0,6875	- 1-5/16 = 1,3125	- 1-15/16 = 1,9375
- 3/4 = 0,75	- 1-3/8 = 1,375	- 2 = 2,0
- 13/16 = 0,8125	- 1-7/16 = 1,4375	- 2-1/4 = 2,25

Satuan : inch

(hlm : 374)

**Lampiran 7. Perhitungan Ketebalan Nozzle**

Unit	Size (in)	t	Schedule Nozzle	t nozzle	tn	Di nozzle	Di	Rn	trn
				(required)	corr	(required)	corr		
N1	6	0.204449	STD	0.219	0.10089	6.187	6.42322	3.21161	0.088928
N2	4	0.17676	STD	0.188	0.06989	4.124	4.36022	2.18011	0.060366
N3	3	0.162915	STD	0.188	0.06989	3.214	3.45022	1.72511	0.047768
N4	4	0.17676	STD	0.188	0.06989	3.124	3.36022	1.68011	0.046522
N5	2	0.14907	40	0.154	0.03589	2.067	2.30322	1.15161	0.031888
N6	2	0.14907	40	0.154	0.03589	2.067	2.30322	1.15161	0.031888
K1 A/B	2	0.14907	40	0.154	0.03589	2.067	2.30322	1.15161	0.031888
K2 A/B	2	0.14907	40	0.154	0.03589	2.067	2.30322	1.15161	0.031888
K3	2	0.14907	40	0.154	0.03589	2.067	2.30322	1.15161	0.031888
K4 A/B	2	0.14907	40	0.154	0.03589	2.067	2.30322	1.15161	0.031888
K5 A/B	2	0.14907	40	0.154	0.03589	2.067	2.30322	1.15161	0.031888
M1	20	0.398277	STD	0.438	0.31989	19.124	19.36022	9.68011	0.268039

**Lampiran 8. Element Thickness.**

**Element Thickness, Pressure, Diameter and Allowable Stress :**

From	To	Int. Press + Liq. Hd psig	Nominal Thickness in.	Total Corr Allowance in.	Element Diameter in.	Allowable Stress(SE) psi
skirt		...	0.31496	0.11811	51.1810	...
bottom head		580.151	1.14173	0.11811	51.1810	19212.0
shell		580.151	1.18110	0.11811	51.1810	19212.0
top Head		580.151	1.14173	0.11811	51.1810	19212.0

**Element Required Thickness and MAWP :**

From	To	Design Pressure psig	M.A.W.P. Corroded psig	M.A.P. New & Cold psig	Minimum Thickness in.	Required Thickness in.
skirt		...	No Calc	No Calc	0.31496	No Calc
bottom head		580.151	747.101	853.344	1.14173	0.89206
shell		580.151	775.141	862.814	1.18110	0.90877
top Head		580.151	747.101	853.344	1.14173	0.89206
Minimum			668.000	740.000		

## **Lampiran 9. Internal Pressure.**

### **Internal Pressure Calculation Results :**

**ASME Code, Section VIII, Division 1, 2013**

### **Elliptical Head From 30 To 40 SA-516 60 , UCS-66 Crv. D at 248 °F**

bottom head

Material UNS Number: K02100

Required Thickness due to Internal Pressure [tr]:

$$\begin{aligned} &= (P \cdot D \cdot K_{cor}) / (2 \cdot S \cdot E - 0.2 \cdot P) \text{ Appendix 1-4 (c)} \\ &= (580.151 \cdot 51.4172 \cdot 0.994) / (2 \cdot 19212.00 \cdot 1.00 - 0.2 \cdot 580.151) \\ &= 0.7739 + 0.1181 = 0.8921 \text{ in.} \end{aligned}$$

Max. Allowable Working Pressure at given Thickness, corroded [MAWP]:

$$\begin{aligned} &= (2 \cdot S \cdot E \cdot t) / (K_{cor} \cdot D + 0.2 \cdot t) \text{ per Appendix 1-4 (c)} \\ &= (2 \cdot 19212.00 \cdot 1.00 \cdot 1.0236) / (0.994 \cdot 51.4172 + 0.2 \cdot 1.0236) \\ &= 766.561 \text{ psig} \end{aligned}$$

Maximum Allowable Pressure, New and Cold [MAPNC]:

$$\begin{aligned} &= (2 \cdot S \cdot E \cdot t) / (K \cdot D + 0.2 \cdot t) \text{ per Appendix 1-4 (c)} \\ &= (2 \cdot 19212.00 \cdot 1.00 \cdot 1.1417) / (1.000 \cdot 51.1810 + 0.2 \cdot 1.1417) \\ &= 853.344 \text{ psig} \end{aligned}$$

Actual stress at given pressure and thickness, corroded [Sact]:

$$\begin{aligned} &= (P \cdot (K_{cor} \cdot D + 0.2 \cdot t)) / (2 \cdot E \cdot t) \\ &= (580.151 \cdot (0.994 \cdot 51.4172 + 0.2 \cdot 1.0236)) / (2 \cdot 1.00 \cdot 1.0236) \\ &= 14540.089 \text{ psi} \end{aligned}$$

**Straight Flange Required Thickness:**

$$\begin{aligned} &= (P \cdot R) / (S \cdot E - 0.6 \cdot P) + c \quad \text{per UG-27 (c) (1)} \\ &= (580.151 \cdot 25.7086) / (19212.00 \cdot 1.00 - 0.6 \cdot 580.151) + 0.118 \\ &= 0.909 \text{ in.} \end{aligned}$$

**Straight Flange Maximum Allowable Working Pressure:**

$$\begin{aligned} &= (S \cdot E \cdot t) / (R + 0.6 \cdot t) \quad \text{per UG-27 (c) (1)} \\ &= (19212.00 \cdot 1.00 \cdot 1.0236) / (25.7086 + 0.6 \cdot 1.0236) \\ &= 747.101 \text{ psig} \end{aligned}$$

**Factor K, corroded condition [Kcor]:**

$$\begin{aligned} &= ( 2 + ( \text{Inside Diameter} / ( 2 \cdot \text{Inside Head Depth} ) )^2 ) / 6 \\ &= ( 2 + ( 51.417 / ( 2 \cdot 12.913 ) )^2 ) / 6 \\ &= 0.993916 \end{aligned}$$

Percent Elong. per UCS-79, VIII-1-01-57  $(75 \cdot t_{nom} / R_f) \cdot (1 - R_f / R_o)$  9.236 %

**Note:** Please Check Requirements of UCS-79 as Elongation is > 5%.

**MDMT Calculations in the Knuckle Portion:**

Govrn. thk,  $t_g = 1.142$  ,  $t_r = 0.892$  ,  $c = 0.1181$  in. ,  $E^* = 1.00$

Stress Ratio =  $t_r \cdot (E^*) / (t_g - c) = 0.871$  , Temp. Reduction = 13 °F

Min Metal Temp. w/o impact per UCS-66, Curve D -24 °F

Min Metal Temp. at Required thickness (UCS 66.1) -37 °F

**MDMT Calculations in the Head Straight Flange:**

Govrn. thk,  $t_g = 1.142$  ,  $t_r = 0.913$  ,  $c = 0.1181$  in. ,  $E^* = 1.00$

Stress Ratio =  $t_r \cdot (E^*) / (t_g - c) = 0.892$  , Temp. Reduction = 11 °F

Min Metal Temp. w/o impact per UCS-66, Curve D	-24 °F
Min Metal Temp. at Required thickness (UCS 66.1)	-35 °F

Note: Post Weld Heat Treatment is required for this Element/Joint.

**Cylindrical Shell From 40 To 50 SA-516 60 , UCS-66 Crv. D at 248 °F**

shell

Material UNS Number: K02100

Required Thickness due to Internal Pressure [tr]:

$$\begin{aligned} &= (P \cdot R) / (S \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\ &= (580.151 \cdot 25.7086) / (19212.00 \cdot 1.00 - 0.6 \cdot 580.151) \\ &= 0.7907 + 0.1181 = 0.9088 \text{ in.} \end{aligned}$$

Max. Allowable Working Pressure at given Thickness, corroded [MAWP]:

$$\begin{aligned} &= (S \cdot E \cdot t) / (R + 0.6 \cdot t) \text{ per UG-27 (c) (1)} \\ &= (19212.00 \cdot 1.00 \cdot 1.0630) / (25.7086 + 0.6 \cdot 1.0630) \\ &= 775.141 \text{ psig} \end{aligned}$$

Maximum Allowable Pressure, New and Cold [MAPNC]:

$$\begin{aligned} &= (S \cdot E \cdot t) / (R + 0.6 \cdot t) \text{ per UG-27 (c) (1)} \\ &= (19212.00 \cdot 1.00 \cdot 1.1811) / (25.5905 + 0.6 \cdot 1.1811) \\ &= 862.814 \text{ psig} \end{aligned}$$

Actual stress at given pressure and thickness, corroded [Sact]:

$$\begin{aligned} &= (P \cdot (R + 0.6 \cdot t)) / (E \cdot t) \\ &= (580.151 \cdot (25.7086 + 0.6 \cdot 1.0630)) / (1.00 \cdot 1.0630) \\ &= 14379.149 \text{ psi} \end{aligned}$$



Percent Elongation per UCS-79  $(50 \cdot t_{nom} / R_f) \cdot (1 - R_f / R_o)$  2.256 %

**Minimum Design Metal Temperature Results:**

Govrn. thk,  $t_g = 1.181$  ,  $t_r = 0.913$  ,  $c = 0.1181$  in. ,  $E^* = 1.00$

Stress Ratio =  $t_r \cdot (E^*) / (t_g - c) = 0.859$  , Temp. Reduction = 14 °F

Min Metal Temp. w/o impact per UCS-66, Curve D -23 °F

Min Metal Temp. at Required thickness (UCS 66.1) -37 °F

Note: Post Weld Heat Treatment is required for this Element/Joint.

**Elliptical Head From 50 To 60 SA-516 60 , UCS-66 Crv. D at 248 °F**

top Head

Material UNS Number: K02100

Required Thickness due to Internal Pressure [tr]:

$$\begin{aligned} &= (P \cdot D \cdot K_{cor}) / (2 \cdot S \cdot E - 0.2 \cdot P) \text{ Appendix 1-4 (c)} \\ &= (580.151 \cdot 51.4172 \cdot 0.994) / (2 \cdot 19212.00 \cdot 1.00 - 0.2 \cdot 580.151) \\ &= 0.7739 + 0.1181 = 0.8921 \text{ in.} \end{aligned}$$

Max. Allowable Working Pressure at given Thickness, corroded [MAWP]:

$$\begin{aligned} &= (2 \cdot S \cdot E \cdot t) / (K_{cor} \cdot D + 0.2 \cdot t) \text{ per Appendix 1-4 (c)} \\ &= (2 \cdot 19212.00 \cdot 1.00 \cdot 1.0236) / (0.994 \cdot 51.4172 + 0.2 \cdot 1.0236) \\ &= 766.561 \text{ psig} \end{aligned}$$

Maximum Allowable Pressure, New and Cold [MAPNC]:

$$= (2 \cdot S \cdot E \cdot t) / (K \cdot D + 0.2 \cdot t) \text{ per Appendix 1-4 (c)}$$

$$= (2*19212.00*1.00*1.1417) / (1.000*51.1810+0.2*1.1417)$$

$$= 853.344 \text{ psig}$$

**Actual stress at given pressure and thickness, corroded [Sact]:**

$$= (P*(Kcor*D+0.2*t)) / (2*E*t)$$

$$= (580.151*(0.994*51.4172+0.2*1.0236)) / (2*1.00*1.0236)$$

$$= 14540.089 \text{ psi}$$

**Straight Flange Required Thickness:**

$$= (P*R) / (S*E-0.6*P) + c \quad \text{per UG-27 (c) (1)}$$

$$= (580.151*25.7086) / (19212.00*1.00-0.6*580.151)+0.118$$

$$= 0.909 \text{ in.}$$

**Straight Flange Maximum Allowable Working Pressure:**

$$= (S*E*t) / (R+0.6*t) \quad \text{per UG-27 (c) (1)}$$

$$= (19212.00 * 1.00 * 1.0236) / (25.7086 + 0.6 * 1.0236)$$

$$= 747.101 \text{ psig}$$

**Factor K, corroded condition [Kcor]:**

$$= ( 2 + ( \text{Inside Diameter} / ( 2 * \text{Inside Head Depth} ) )^2 ) / 6$$

$$= ( 2 + ( 51.417 / ( 2 * 12.913 ) )^2 ) / 6$$

$$= 0.993916$$

Percent Elong. per UCS-79, VIII-1-01-57  $(75*t_{nom}/R_f) * (1-R_f/R_o) = 9.236 \%$

**Note: Please Check Requirements of UCS-79 as Elongation is > 5%.**

**MDMT Calculations in the Knuckle Portion:**

Govrn. thk,  $t_g = 1.142$  ,  $t_r = 0.892$  ,  $c = 0.1181$  in. ,  $E^* = 1.00$

Stress Ratio =  $t_r * (E^*) / (t_g - c) = 0.871$  , Temp. Reduction =  $13^\circ\text{F}$

Min Metal Temp. w/o impact per UCS-66, Curve D	-24 °F
Min Metal Temp. at Required thickness (UCS 66.1)	-37 °F

**MDMT Calculations in the Head Straight Flange:**

Govrn. thk,  $t_g = 1.142$  ,  $t_r = 0.913$  ,  $c = 0.1181$  in. ,  $E^* = 1.00$

Stress Ratio =  $t_r * (E^*) / (t_g - c) = 0.892$  , Temp. Reduction = 11 °F

Min Metal Temp. w/o impact per UCS-66, Curve D	-24 °F
Min Metal Temp. at Required thickness (UCS 66.1)	-35 °F

Note: Post Weld Heat Treatment is required for this Element/Joint.

**Lampiran 10. Tes Tekanan Hidrostatik.**

**Hydrostatic Test Pressure Results:**

Pressure per UG99b	= 1.3 * M.A.W.P. * Sa/S	868.400	psig
Pressure per UG99b[34]	= 1.3 * Design Pres * Sa/S	754.196	psig
Pressure per UG99c	= 1.3 * M.A.P. - Head(Hyd)	962.000	psig
Pressure per UG100	= 1.1 * M.A.W.P. * Sa/S	734.800	psig
Pressure per PED	= 1.43 * MAWP	955.240	psig

UG-99(b), Test Pressure Calculation:

= Test Factor \* MAWP \* Stress Ratio  
= 1.3 \* 668.000 \* 1.000  
= 868.400 psig

**Horizontal Test performed per: UG-99b**

*Please note that Nozzle, Shell, Head, Flange, etc MAWPs are all considered when determining the hydrotest pressure for those test types that are based*

*on the MAWP of the vessel.*

**Stresses on Elements due to Test Pressure:**

From To	Stress	Allowable	Ratio	Pressure
-----				
bottom head	19592.6	22230.0	0.881	870.25
shell	19377.5	22230.0	0.872	870.25
top Head	19592.6	22230.0	0.881	870.25
-----				

Elements Suitable for Internal Pressure.

**PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2014**

## **Lampiran 11. Wind Load.**

### **Input Values:**

Wind Design Code		ASCE-7 95
Basic Wind Speed	[V]	100.70 mile/hr
Surface Roughness Category		C: Open Terrain
Importance Factor		1.0
Type of Surface		Moderately Smooth
Base Elevation		0.0000 ft.
Percent Wind for Hydrotest		33.0
Using User defined Wind Press. Vs Elev.		N
Height of Hill or Escarpment	H or Hh	0.0000 ft.
Distance Upwind of Crest	Lh	0.0000 ft.
Distance from Crest to the Vessel	x	0.0000 ft.
Type of Terrain ( Hill, Escarpment )		Flat
Damping Factor (Beta) for Wind (Ope)		0.0100
Damping Factor (Beta) for Wind (Empty)		0.0000
Damping Factor (Beta) for Wind (Filled)		0.0000

### **Wind Analysis Results**

Dynamic Gust-Effect Factor, Operating Case [Gf]:

$$\begin{aligned} &= ( 1 + 2 * G * Zbar * \text{sqrt}( Q2 + R2 ) ) / ( 1 + 7 * Zbar ) \\ &= (1+2*3.500*0.228*\text{sqrt}(0.908+0.009)) / (1+7*0.228) \\ &= 0.974 \end{aligned}$$

Natural Frequency of Vessel (Operating)	14.124 Hz
Natural Frequency of Vessel (Empty)	14.124 Hz
Natural Frequency of Vessel (Test)	12.130 Hz

Note: Per Section 1609 of IBC 2003/06/09 these results are also applicable

for the determination of Wind Loads on structures (1609.1.1).

User Entered Importance Factor is	1.000
Force Coefficient	[Cf] 0.557
Structure Height to Diameter ratio	4.398
Height to top of Structure	19.206 ft.

*This is classified as a flexible structure. Dynamic analysis performed.*

### **Sample Calculation for the First Element**

The ASCE code performs all calculations in Imperial Units only. The wind pressure is therefore computed in these units.

Value of [Alpha] and [Zg]:

Exposure Category: C from Table C6-2  
Alpha = 9.500 : Zg = 900.000 ft.

Effective Height [z]:

= Centroid Height + Vessel Base Elevation  
= 2.461 + 0.000 = 2.461 ft.

Velocity Pressure coefficient evaluated at height z [Kz]:

Because z (2.461 ft.) < 15 ft.  
= 2.01 \* ( 15 / Zg ) <sup>2 / Alpha</sup>  
= 2.01 \* ( 15/900.000 ) <sup>2/9.500</sup>  
= 0.849

Type of Hill: No Hill

As there is No Hill Present: [Kzt]:

$$K1 = 0, K2 = 0, K3 = 0$$

Topographical Factor [Kzt]:

$$\begin{aligned} &= ( 1 + K1 * K2 * K3 )^2 \\ &= ( 1 + 0.000 * 0.000 * 0.000 )^2 \\ &= 1.0000 \end{aligned}$$

Velocity Pressure evaluated at height z, Imperial Units [qz]:

$$\begin{aligned} &= 0.00256 * Kz * Kzt * Kd * I * Vr (\text{mph})^2 \\ &= 0.00256 * 0.849 * 1.000 * 1.000 * 1.000 * 100.700^2 \\ &= 22.0 \text{ psf} \end{aligned}$$

Force on the first element [F]:

$$\begin{aligned} &= qz * Gf * Cf * \text{WindArea} \\ &= 22.037 * 0.974 * 0.557 * 25.497 \\ &= 304.6 \text{ lb.} \end{aligned}$$

Element	Hgt (z) ft.	K1	K2	K3	Kz	Kzt	qz psf
skirt	2.5	0.000	0.000	0.000	0.849	1.000	22.037
bottom head	4.9	0.000	0.000	0.000	0.849	1.000	22.037
shell	11.5	0.000	0.000	0.000	0.849	1.000	22.037
top Head	18.5	0.000	0.000	0.000	0.888	1.000	23.041

### **Wind Vibration Calculations**

This evaluation is based on work by Kanti Mahajan and Ed Zorilla

### **Nomenclature**

Cf - Correction factor for natural frequency  
 D - Average internal diameter of vessel ft.  
 Df - Damping Factor < 0.75 Unstable, > 0.95 Stable  
 Dr - Average internal diameter of top half of vessel ft.  
 f - Natural frequency of vibration (Hertz)  
 fl - Natural frequency of bare vessel based on a unit value of  $(D/L^2) (10^4)$   
 L - Total height of structure ft.  
 Lc - Total length of conical section(s) of vessel ft.  
 tb - Uncorroded plate thickness at bottom of vessel in.  
 V30 - Design Wind Speed provided by user mile/hr  
 Vc - Critical wind velocity mile/hr  
 Vw - Maximum wind speed at top of structure mile/hr  
 W - Total corroded weight of structure lb.  
 Ws - Cor. vessel weight excl. weight of parts which do not effect stiff.  
 lb.  
 Z - Maximum amplitude of vibration at top of vessel in.  
 Dl - Logarithmic decrement ( taken as 0.03 for Welded Structures )  
 Vp - Vib. Chance,  $\leq 0.200E+02$  (High);  $0.200E+02 < 0.250E+02$  (Probable)  
 P30 - wind pressure 30 feet above the base

**Check other Conditions and Basic Assumptions:**

#1 - Total Cone Length / Total Length < 0.5

$$0.000/18.045 = 0.000$$

#2 -  $( D / L^2 ) * 10^4 < 8.0$  (English Units)

$$- ( 4.42/18.04^2 ) * 10^4 = 135.826 \text{ [Geometry Violation]}$$

**Compute the vibration possibility. If  $V_p > 0.250E+02$  no chance. [Vp]:**

$$= W / ( L * D_r^2 )$$

$$= 12047 / ( 18.04 * 4.285^2 )$$



= 0.36367E+02

Since  $V_p$  is  $> 0.250E+02$  no further vibration analysis is required !

The Natural Frequency for the Vessel (Ope...) is 14.1236 Hz.

### **Wind Load Calculation**

		Wind	Wind	Wind	Wind	Element
From	To	Height	Diameter	Area	Pressure	Wind Load
		ft.	ft.	sq.in.	psf	lb.
-----						
20	30	2.46062	5.18109	3671.63	22.0367	304.560
30	40	4.92120	5.34645	0.076989	22.0367	0.0063862
40	50	11.4829	5.35432	10118.4	22.0367	839.313
50	60	18.5374	5.34645	702.348	23.0413	60.9153

**PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2014**

**Lampiran 12. Seismic Load.**

**Earthquake Analysis Results**

The UBC Zone Factor for the Vessel is ..... 0.1500  
 The Importance Factor as Specified by the User is . 1.000  
 The UBC Frequency and Soil Factor (C) is ..... 2.750  
 The UBC Force Factor as Specified by the User is .. 3.000  
 The UBC Total Weight (W) for the Vessel is ..... 13418.7 lb.  
 The UBC Total Shear (V) for the Vessel is ..... 1845.1 lb.  
 The UBC Top Shear (Ft) for the Vessel is ..... 0.0 lb.

The Natural Frequency for the Vessel (Ope...) is 14.1236 Hz.

**Earthquake Load Calculation**

From	To	Earthquake Height ft.	Earthquake Weight lb.	Element Ope Load lb.	Element Emp Load lb.
20	30	2.46062	1762.32	57.9108	57.9108
30	40	4.92120	1114.92	73.2733	73.2733
40	50	11.4829	9430.34	1446.13	1446.13
50	60	18.0445	1111.12	267.754	267.754
Top Load		19.11		0	0

### Lampiran 13. MAWP Flange.

#### Nozzle Flange MAWP Results :

Nozzle Description	----- Flange Rating		Temperature °F	Class	Grade Group
	Operating psig	Ambient psig			
-----					
N3	888.2	985.0	248	400	GR 1.1
N1	888.2	985.0	248	400	GR 1.1
N4	888.2	985.0	248	400	GR 1.1
N6	888.2	985.0	248	400	GR 1.1
K1A	888.2	985.0	248	400	GR 1.1
K2A	888.2	985.0	248	400	GR 1.1
K3	888.2	985.0	248	400	GR 1.1
M1	888.2	985.0	248	400	GR 1.1
K4	888.2	985.0	248	400	GR 1.1
K5	888.2	985.0	248	400	GR 1.1
N2	888.2	985.0	248	400	GR 1.1
N5	888.2	985.0	248	400	GR 1.1
-----					
Minimum Rating	888.200	985.000	psig	(for Core Elements)	

Note: ANSI Ratings are per ANSI/ASME B16.5 2009 Edition

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2014

## Lampiran 14. Data Nozzle.

### Nozzle Schedule:

Description	Nominal Flange		Noz. O/Dia in.	Wall Thk in.	Re-Pad		Cut Length in.	
	Size in.	Sch/Type Cls			ODia in.	Thick in.		
N6	2.000	160	WNF	2.375	0.344	-	-	7.22
K1A	2.000	160	WNF	2.375	0.344	-	-	7.22
K2A	2.000	160	WNF	2.375	0.344	-	-	7.24
K3	2.000	300	WNF	2.624	0.312	-	-	7.23
K4	2.000	160	WNF	2.375	0.344	-	-	7.22
K5	2.000	160	WNF	2.375	0.344	-	-	7.22
N5	2.000	300	WNF	2.600	0.300	-	-	8.06
N3	3.000	300	WNF	3.812	0.406	-	-	7.21
N4	4.000	300	WNF	4.690	0.345	-	-	12.11
N2	4.000	300	WNF	4.750	0.375	-	-	7.23
N1	6.000	300	WNF	6.800	0.400	-	-	9.50
M1	20.000	40	WNF	20.000	0.593	-	-	13.77

### Nozzle Material and Weld Fillet Leg Size Details:

Nozzle	Material	Shl Grve	Noz Shl/Pad	Pad OD	Pad Grve	Inside
		Weld in.	Weld in.	Weld in.	Weld in.	Weld in.
N6	SA-105	1.181	0.375	-	-	-
K1A	SA-105	1.181	1.000	-	-	-
K2A	SA-105	1.181	0.500	-	-	-
K3	SA-105	0.875	0.375	-	-	-
K4	SA-105	0.875	0.375	-	-	-
K5	SA-105	0.875	0.375	-	-	-
N5	SA-105	1.142	0.375	-	-	-
N3	SA-105	1.142	0.375	-	-	-
N4	SA-105	1.181	0.500	-	-	-
N2	SA-105	1.142	0.375	-	-	-
N1	SA-105	1.181	0.375	-	-	-
M1	SA-105	0.875	0.375	-	-	-

Note: The Outside projections below do not include the flange thickness.

**Nozzle Miscellaneous Data:**

Nozzle	Elevation/Distance	Layout Angle deg.	Projection		Installed In Component
	From Datum ft.		Outside in.	Inside in.	
N6	1.000	180.00	6.00	0.00	shell
K1A	4.000	0.00	6.00	0.00	shell
K2A	3.000	180.00	6.00	0.00	shell
K3	11.300	0.00	6.00	0.00	shell
K4	9.000	0.00	6.00	0.00	shell
K5	7.000	0.00	6.00	0.00	shell
N5		0.00	6.00	0.00	top Head
N3		0.00	6.00	0.00	bottom head
N4	11.483	180.00	10.75	0.00	shell
N2		0.00	6.00	0.00	top Head
N1	5.577	180.00	8.00	0.00	shell
M1	3.000	270.00	10.00	0.00	shell

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2014

**Nozzle Calculation Summary:**

Description	MAWP psig	Ext	MAPNC psig	UG45 [tr]	Weld Path	Areas or Stresses
N3	747.10	OK	...	OK 0.316	OK	Passed
N1	775.14	OK	...	OK 0.400	OK	Passed
N4	775.14	OK	...	OK 0.344	OK	Passed
N6	775.14	OK	...	OK 0.253	OK	Passed
K1A	775.14	OK	...	OK 0.253	OK	Passed
K2A	775.14	OK	...	OK 0.253	OK	Passed
K3	775.14	OK	...	OK 0.296	OK	Passed
M1	681.96	OK	...	OK 0.446	OK	Passed
K4	775.14	OK	...	OK 0.253	OK	Passed
K5	775.14	OK	...	OK 0.253	OK	Passed
N2	692.23	OK	...	OK 0.344	OK	Passed
N5	747.10	OK	...	OK 0.296	OK	Passed
N5	747.10	OK	...	OK 0.296	OK	Passed
Min. - Nozzles	681.96	M1				
Min. Shell&Flgs	668.00					
Computed Vessel M.A.W.P. 668.00 psig						

From Node	Nozzle Description	Y Coordinate,	Layout Angle,	Dia. Limit
30	N3	0.000	0.000	6.472
40	N1	66.929	180.000	25.008
40	N4	137.795	180.000	23.008
40	N6	12.000	180.000	19.695
40	K1A	48.000	0.000	19.695
40	K2A	36.000	180.000	20.445
40	K3	135.600	0.000	20.008
40	M1	36.000	270.000	39.422
40	K4	108.000	0.000	19.695
40	K5	84.000	0.000	19.695
50	N2	0.000	0.000	8.472
50	N5	0.000	0.000	5.797

**The nozzle spacing is computed by the following:**

=  $\text{Sqrt}(l_l^2 + l_c^2)$  where

$l_l$  - Arc length along the inside vessel surface in the long. direction.

$l_c$  - Arc length along the inside vessel surface in the circ. direction

## Lampiran 15. Luas Area Penguat *Nozzle*

- *Nozzle N1*

$$\begin{aligned} \text{Area Required [A]:} \\ &= 0.5( d * tr*F + 2 * tn * tr*F * (1-fr1) ) \text{ per UG-37(d) or UG-39} \\ &= 0.5(6.2362*0.2733*1+2*0.8819*0.2733*1*(1-1.00)) \\ &= 2.652 \text{ sq.in.} \end{aligned}$$

Note: The required area has been increased by the tapped hole area loss.

### Reinforcement Areas per Figure UG-37.1

$$\begin{aligned} \text{Area Available in Shell [A1]:} \\ &= d( E1*t - F*tr ) - 2 * tn( E1*t - F*tr ) * ( 1 - fr1 ) \\ &= 6.236 ( 1.00 * 1.0630 - 1.0 * 0.273 ) - 2 * 0.882 \\ &\quad ( 1.00 * 1.0630 - 1.0 * 0.2733 ) * ( 1 - 1.000 ) \\ &= 4.925 \text{ sq.in.} \end{aligned}$$

$$\begin{aligned} \text{Area Available in Nozzle Projecting Outward [A2]:} \\ &= ( 2 * tlnp ) * ( tn - trn ) * fr2 \\ &= ( 2 * 2.205 ) * ( 0.2819 - 0.0232 ) * 1.0000 \\ &= 1.141 \text{ sq.in.} \end{aligned}$$

$$\begin{aligned} \text{Area Available in Inward Weld + Outward Weld [A41 + A43]:} \\ &= Wo^2 * fr2 + ( Wi-can/0.707 )^2 * fr2 \\ &= 0.3750^2 * 1.0000 + ( 0.0000 )^2 * 1.0000 \\ &= 0.141 \text{ sq.in.} \end{aligned}$$

$$\begin{aligned} \text{Area Available in the Hub Section [A6]:} \\ &= ( 2 * \min(Tlnp,ho,Hubht) ) * (Hubtk - tn) * fr2 \\ &= ( 2 * \min(2.205 ,8.000 ,3.000 ) ) * (1.0000 - 0.4000 ) * 1.000 ) \\ &= 2.646 \text{ sq.in.} \end{aligned}$$

- *Nozzle N2*

Area Required [A]:

$$\begin{aligned}
 &= ( d * tr * F + 2 * tn * tr * F * (1 - fr1) ) \text{ UG-37(c)} \\
 &= ( 4.2362 * 0.6978 * 1.0 + 2 * 0.7569 * 0.6978 * 1.0 * (1 - 1.00) ) \\
 &= 2.956 \text{ sq.in.}
 \end{aligned}$$

**Reinforcement Areas per Figure UG-37.1**

Area Available in Shell [A1]:

$$\begin{aligned}
 &= d ( E1 * t - F * tr ) - 2 * tn ( E1 * t - F * tr ) * ( 1 - fr1 ) \\
 &= 4.236 ( 1.00 * 1.0236 - 1.0 * 0.698 ) - 2 * 0.757 \\
 &\quad ( 1.00 * 1.0236 - 1.0 * 0.6978 ) * ( 1 - 1.000 ) \\
 &= 1.380 \text{ sq.in.}
 \end{aligned}$$

Area Available in Nozzle Projecting Outward [A2]:

$$\begin{aligned}
 &= ( 2 * tlnp ) * ( tn - trn ) * fr2 \\
 &= ( 2 * 1.892 ) * ( 0.2569 - 0.0625 ) * 1.0000 \\
 &= 0.736 \text{ sq.in.}
 \end{aligned}$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$\begin{aligned}
 &= Wo * fr2 + ( Wi - can / 0.707 ) * fr2 \\
 &= 0.3750 * 1.0000 + ( 0.0000 ) * 1.0000 \\
 &= 0.141 \text{ sq.in.}
 \end{aligned}$$

Area Available in the Hub Section [A6]:

$$\begin{aligned}
 &= ( 2 * \min(Tlnp, ho, Hubht) ) * ( Hubtk - tn ) * fr2 \\
 &= ( 2 * \min(1.892, 6.000, 3.000) ) * ( 0.8750 - 0.3750 ) * 1.000 ) \\
 &= 1.892 \text{ sq.in.}
 \end{aligned}$$



- **Nozzle N3**

Area Required [A]:

$$\begin{aligned}
 &= ( d * tr * F + 2 * tn * tr * F * (1 - fr1) ) \text{ UG-37(c)} \\
 &= ( 3.2362 * 0.6978 * 1.0 + 2 * 0.8819 * 0.6978 * 1.0 * (1 - 1.00) ) \\
 &= 2.258 \text{ sq.in.}
 \end{aligned}$$

**Reinforcement Areas per Figure UG-37.1**

Area Available in Shell [A1]:

$$\begin{aligned}
 &= d ( E1 * t - F * tr ) - 2 * tn ( E1 * t - F * tr ) * ( 1 - fr1 ) \\
 &= 3.236 ( 1.00 * 1.0236 - 1.0 * 0.698 ) - 2 * 0.882 \\
 &\quad ( 1.00 * 1.0236 - 1.0 * 0.6978 ) * ( 1 - 1.000 ) \\
 &= 1.055 \text{ sq.in.}
 \end{aligned}$$

Area Available in Nozzle Projecting Outward [A2]:

$$\begin{aligned}
 &= ( 2 * tlnp ) * ( tn - trn ) * fr2 \\
 &= ( 2 * 1.749 ) * ( 0.2879 - 0.0478 ) * 1.0000 \\
 &= 0.840 \text{ sq.in.}
 \end{aligned}$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$\begin{aligned}
 &= Wo^s * fr2 + ( Wi - can / 0.707 )^s * fr2 \\
 &= 0.3750^s * 1.0000 + ( 0.0000 )^s * 1.0000 \\
 &= 0.141 \text{ sq.in.}
 \end{aligned}$$

Area Available in the Hub Section [A6]:

$$\begin{aligned}
 &= ( 2 * \min(Tlnp, ho, Hubht) ) * ( Hubtk - tn ) * fr2 \\
 &= ( 2 * \min(1.749, 6.000, 2.000) ) * ( 1.0000 - 0.4060 ) * 1.000 ) \\
 &= 2.077 \text{ sq.in.}
 \end{aligned}$$

- **Nozzle N4**

Area Required [A]:

$$\begin{aligned}
 &= 0.5( d * tr * F + 2 * tn * tr * F * (1 - fr1) ) \text{ per UG-37(d) or UG-39} \\
 &= 0.5( 4.2362 * 0.2733 * 1 + 2 * 0.8819 * 0.2733 * 1 * (1 - 1.00) ) \\
 &= 2.379 \text{ sq.in.}
 \end{aligned}$$

Note: The required area has been increased by the tapped hole area loss.

**Reinforcement Areas per Figure UG-37.1**

Area Available in Shell [A1]:

$$\begin{aligned}
 &= d( E1 * t - F * tr ) - 2 * tn( E1 * t - F * tr ) * ( 1 - fr1 ) \\
 &= 4.236 ( 1.00 * 1.0630 - 1.0 * 0.273 ) - 2 * 0.882 \\
 &\quad ( 1.00 * 1.0630 - 1.0 * 0.2733 ) * ( 1 - 1.000 ) \\
 &= 3.345 \text{ sq.in.}
 \end{aligned}$$

Area Available in Nozzle Projecting Outward [A2]:

$$\begin{aligned}
 &= ( 2 * tlnp ) * ( tn - trn ) * fr2 \\
 &= ( 2 * 2.205 ) * ( 0.2269 - 0.0210 ) * 1.0000 \\
 &= 0.908 \text{ sq.in.}
 \end{aligned}$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$\begin{aligned}
 &= Wo^s * fr2 + ( Wi - can / 0.707 )^s * fr2 \\
 &= 0.5000^s * 1.0000 + ( 0.0000 )^s * 1.0000 \\
 &= 0.250 \text{ sq.in.}
 \end{aligned}$$

Area Available in the Hub Section [A6]:

$$\begin{aligned}
 &= ( 2 * \min( Tlnp, ho, Hubht ) ) * ( Hubtk - tn ) * fr2 \\
 &= ( 2 * \min( 2.205, 10.750, 4.000 ) ) * ( 1.0000 - 0.3450 ) * 1.000 ) \\
 &= 2.888 \text{ sq.in.}
 \end{aligned}$$

- **Nozzle N5**

Area Required [A]:

$$\begin{aligned}
 &= ( d * tr * F + 2 * tn * tr * F * (1 - fr1) ) \text{ UG-37(c)} \\
 &= ( 2.4933 * 0.7739 * 1.0 + 2 * 0.7569 * 0.7739 * 1.0 * (1 - 1.00) ) \\
 &= 1.930 \text{ sq.in.}
 \end{aligned}$$

**Reinforcement Areas per Figure UG-37.1**

Area Available in Shell [A1]:

$$\begin{aligned}
 &= d ( E1 * t - F * tr ) - 2 * tn ( E1 * t - F * tr ) * ( 1 - fr1 ) \\
 &= 3.561 ( 1.00 * 1.0236 - 1.0 * 0.774 ) - 2 * 0.757 \\
 &\quad ( 1.00 * 1.0236 - 1.0 * 0.7739 ) * ( 1 - 1.000 ) \\
 &= 0.889 \text{ sq.in.}
 \end{aligned}$$

Area Available in Nozzle Projecting Outward [A2]:

$$\begin{aligned}
 &= ( 2 * tlnp ) * ( tn - trn ) * fr2 / \sin( \alpha3 ) \\
 &= ( 2 * 1.892 ) * ( 0.1819 - 0.0330 ) * 1.0000 / \sin( 67.8 ) \\
 &= 0.608 \text{ sq.in.}
 \end{aligned}$$

Note: See ASME VIII-1 2011(a) Appendix L, L-7.7.7(b) for more information.

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$\begin{aligned}
 &= Wo^2 * fr2 + ( Wi - can / 0.707 )^2 * fr2 \\
 &= 0.3750^2 * 1.0000 + ( 0.0000 )^2 * 1.0000 \\
 &= 0.141 \text{ sq.in.}
 \end{aligned}$$

Area Available in the Hub Section [A6]:

$$\begin{aligned}
 &= ( 2 * \min(Tlnp, ho, Hubht) ) * ( Hubtk - tn ) * fr2 \\
 &= ( 2 * \min(1.892, 6.000, 2.000) ) * ( 0.8750 - 0.3000 ) * 1.000 ) \\
 &= 2.176 \text{ sq.in.}
 \end{aligned}$$

- **Nozzle N6**

Area Required [A]:

$$\begin{aligned}
 &= 0.5( d * tr*F + 2 * tn * tr*F * (1-fr1) ) \text{ per UG-37(d) or UG-39} \\
 &= 0.5(1.9232*0.2733*1+2*0.3819*0.2733*1*(1-1.00)) \\
 &= 2.063 \text{ sq.in.}
 \end{aligned}$$

Note: The required area has been increased by the tapped hole area loss.

**Reinforcement Areas per Figure UG-37.1**

Area Available in Shell [A1]:

$$\begin{aligned}
 &= d( E1*t - F*tr ) - 2 * tn( E1*t - F*tr ) * ( 1 - fr1 ) \\
 &= 2.890 ( 1.00 * 1.0630 - 1.0 * 0.273 ) - 2 * 0.382 \\
 &\quad ( 1.00 * 1.0630 - 1.0 * 0.2733 ) * ( 1 - 1.000 ) \\
 &= 2.282 \text{ sq.in.}
 \end{aligned}$$

Area Available in Nozzle Projecting Outward [A2]:

$$\begin{aligned}
 &= ( 2 * tlnp ) * ( tn - trn ) * fr2 \\
 &= ( 2 * 0.955 ) * ( 0.2259 - 0.0111 ) * 1.0000 \\
 &= 0.410 \text{ sq.in.}
 \end{aligned}$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$\begin{aligned}
 &= Wo^a * fr2 + ( Wi-can/0.707 )^a * fr2 \\
 &= 0.3750^a * 1.0000 + ( 0.0000 )^a * 1.0000 \\
 &= 0.141 \text{ sq.in.}
 \end{aligned}$$

Area Available in the Hub Section [A6]:

$$\begin{aligned}
 &= ( 2 * \min(Tlnp,ho,Hubht) ) * (Hubtk - tn) * fr2 \\
 &= ( 2 * \min(0.955 ,6.000 ,2.000 ) ) * (0.5000 - 0.3440 ) * 1.000 ) \\
 &= 0.298 \text{ sq.in.}
 \end{aligned}$$

- **Nozzle K1A**

Area Required [A]:

$$\begin{aligned}
 &= 0.5( d * tr*F + 2 * tn * tr*F * (1-fr1) ) \text{ per UG-37(d) or UG-39} \\
 &= 0.5(1.9232*0.2733*1+2*0.3819*0.2733*1*(1-1.00)) \\
 &= 2.063 \text{ sq.in.}
 \end{aligned}$$

Note: The required area has been increased by the tapped hole area loss.

**Reinforcement Areas per Figure UG-37.1**

Area Available in Shell [A1]:

$$\begin{aligned}
 &= d( E1*t - F*tr ) - 2 * tn( E1*t - F*tr ) * ( 1 - fr1 ) \\
 &= 2.890 ( 1.00 * 1.0630 - 1.0 * 0.273 ) - 2 * 0.382 \\
 &\quad ( 1.00 * 1.0630 - 1.0 * 0.2733 ) * ( 1 - 1.000 ) \\
 &= 2.282 \text{ sq.in.}
 \end{aligned}$$

Area Available in Nozzle Projecting Outward [A2]:

$$\begin{aligned}
 &= ( 2 * tlnp ) * ( tn - trn ) * fr2 \\
 &= ( 2 * 0.955 ) * ( 0.2259 - 0.0111 ) * 1.0000 \\
 &= 0.410 \text{ sq.in.}
 \end{aligned}$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$\begin{aligned}
 &= ( Wo^2 - Area Lost ) * fr2 + ( (Wi-can/0.707)^2 - Area Lost ) * fr2 \\
 &= ( 1.0000^2 - 0.0020 ) * 1.0000 + ( 0.0000^2 - 0.0000 ) * 1.0000 \\
 &= 0.998 \text{ sq.in.}
 \end{aligned}$$

Area Available in the Hub Section [A6]:

$$\begin{aligned}
 &= ( 2 * \min(Tlnp,ho,Hubht) ) * ( Hubtk - tn ) * fr2 \\
 &= ( 2 * \min(0.955 , 6.000 , 2.000 ) ) * ( 0.5000 - 0.3440 ) * 1.000 ) \\
 &= 0.298 \text{ sq.in.}
 \end{aligned}$$

- **Nozzle K2A**

Area Required [A]:

$$\begin{aligned}
 &= 0.5( d * tr * F + 2 * tn * tr * F * (1 - fr1) ) \text{ per UG-37(d) or UG-39} \\
 &= 0.5(1.9232 * 0.2733 * 1 + 2 * 0.7569 * 0.2733 * 1 * (1 - 1.00)) \\
 &= 2.063 \text{ sq.in.}
 \end{aligned}$$

Note: The required area has been increased by the tapped hole area loss.

**Reinforcement Areas per Figure UG-37.1**

Area Available in Shell [A1]:

$$\begin{aligned}
 &= d( E1 * t - F * tr ) - 2 * tn( E1 * t - F * tr ) * ( 1 - fr1 ) \\
 &= 3.640 ( 1.00 * 1.0630 - 1.0 * 0.273 ) - 2 * 0.757 \\
 &\quad ( 1.00 * 1.0630 - 1.0 * 0.2733 ) * ( 1 - 1.000 ) \\
 &= 2.874 \text{ sq.in.}
 \end{aligned}$$

Area Available in Nozzle Projecting Outward [A2]:

$$\begin{aligned}
 &= ( 2 * tlnp ) * ( tn - trn ) * fr2 \\
 &= ( 2 * 1.892 ) * ( 0.2259 - 0.0111 ) * 1.0000 \\
 &= 0.813 \text{ sq.in.}
 \end{aligned}$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$\begin{aligned}
 &= Wo^s * fr2 + ( Wi - can / 0.707 )^s * fr2 \\
 &= 0.5000^s * 1.0000 + ( 0.0000 )^s * 1.0000 \\
 &= 0.250 \text{ sq.in.}
 \end{aligned}$$

Area Available in the Hub Section [A6]:

$$\begin{aligned}
 &= ( 2 * \min(Tlnp, ho, Hubht) ) * ( Hubtk - tn ) * fr2 \\
 &= ( 2 * \min(1.892, 6.000, 2.000) ) * ( 0.8750 - 0.3440 ) * 1.000 ) \\
 &= 2.010 \text{ sq.in.}
 \end{aligned}$$

- **Nozzle K3**

Area Required [A]:

$$\begin{aligned}
 &= 0.5( d * tr*F + 2 * tn * tr*F * (1-fr1) ) \text{ per UG-37(d) or UG-39} \\
 &= 0.5(2.2362*0.2733*1+2*0.3819*0.2733*1*(1-1.00)) \\
 &= 2.106 \text{ sq.in.}
 \end{aligned}$$

Note: The required area has been increased by the tapped hole area loss.

**Reinforcement Areas per Figure UG-37.1**

Area Available in Shell [A1]:

$$\begin{aligned}
 &= d( E1*t - F*tr ) - 2 * tn( E1*t - F*tr ) * ( 1 - fr1 ) \\
 &= 2.890 ( 1.00 * 1.0630 - 1.0 * 0.273 ) - 2 * 0.382 \\
 &\quad ( 1.00 * 1.0630 - 1.0 * 0.2733 ) * ( 1 - 1.000 ) \\
 &= 2.282 \text{ sq.in.}
 \end{aligned}$$

Area Available in Nozzle Projecting Outward [A2]:

$$\begin{aligned}
 &= ( 2 * tlnp ) * ( tn - trn ) * fr2 \\
 &= ( 2 * 0.955 ) * ( 0.1939 - 0.0118 ) * 1.0000 \\
 &= 0.348 \text{ sq.in.}
 \end{aligned}$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$\begin{aligned}
 &= Wo^* * fr2 + ( Wl-can/0.707 )^* * fr2 \\
 &= 0.3750^* * 1.0000 + ( 0.0000 )^* * 1.0000 \\
 &= 0.141 \text{ sq.in.}
 \end{aligned}$$

Area Available in the Hub Section [A6]:

$$\begin{aligned}
 &= ( 2 * \min(Tlnp,ho,Hubht) ) * ( Hubtk - tn ) * fr2 \\
 &= ( 2 * \min(0.955 ,6.000 ,2.000 ) ) * ( 0.5000 - 0.3120 ) * 1.000 ) \\
 &= 0.359 \text{ sq.in.}
 \end{aligned}$$

- **Nozzle K4**

Area Required [A]:

$$\begin{aligned}
 &= 0.5( d * tr * F + 2 * tn * tr * F * (1-fr1) ) \text{ per UG-37(d) or UG-39} \\
 &= 0.5(1.9232 * 0.2733 * 1 + 2 * 0.3819 * 0.2733 * 1 * (1-1.00)) \\
 &= 2.063 \text{ sq.in.}
 \end{aligned}$$

Note: The required area has been increased by the tapped hole area loss.

**Reinforcement Areas per Figure UG-37.1**

Area Available in Shell [A1]:

$$\begin{aligned}
 &= d( E1 * t - F * tr ) - 2 * tn( E1 * t - F * tr ) * ( 1 - fr1 ) \\
 &= 2.890 ( 1.00 * 1.0630 - 1.0 * 0.273 ) - 2 * 0.382 \\
 &\quad ( 1.00 * 1.0630 - 1.0 * 0.2733 ) * ( 1 - 1.000 ) \\
 &= 2.282 \text{ sq.in.}
 \end{aligned}$$

Area Available in Nozzle Projecting Outward [A2]:

$$\begin{aligned}
 &= ( 2 * tlnp ) * ( tn - trn ) * fr2 \\
 &= ( 2 * 0.955 ) * ( 0.2259 - 0.0111 ) * 1.0000 \\
 &= 0.410 \text{ sq.in.}
 \end{aligned}$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$\begin{aligned}
 &= Wo^s * fr2 + ( Wi-can/0.707 )^s * fr2 \\
 &= 0.3750^s * 1.0000 + ( 0.0000 )^s * 1.0000 \\
 &= 0.141 \text{ sq.in.}
 \end{aligned}$$

Area Available in the Hub Section [A6]:

$$\begin{aligned}
 &= ( 2 * \min(Tlnp, ho, Hubht) ) * ( Hubtk - tn ) * fr2 \\
 &= ( 2 * \min(0.955 , 6.000 , 2.000 ) ) * ( 0.5000 - 0.3440 ) * 1.000 ) \\
 &= 0.298 \text{ sq.in.}
 \end{aligned}$$



- **Nozzle K5**

Area Required [A]:

$$\begin{aligned}
 &= 0.5( d * tr * F + 2 * tn * tr * F * (1 - fr1) ) \text{ per UG-37(d) or UG-39} \\
 &= 0.5( 1.9232 * 0.2733 * 1 + 2 * 0.3819 * 0.2733 * 1 * (1 - 1.00) ) \\
 &= 2.063 \text{ sq.in.}
 \end{aligned}$$

Note: The required area has been increased by the tapped hole area loss.

**Reinforcement Areas per Figure UG-37.1**

Area Available in Shell [A1]:

$$\begin{aligned}
 &= d( E1 * t - F * tr ) - 2 * tn( E1 * t - F * tr ) * ( 1 - fr1 ) \\
 &= 2.890 ( 1.00 * 1.0630 - 1.0 * 0.273 ) - 2 * 0.382 \\
 &\quad ( 1.00 * 1.0630 - 1.0 * 0.2733 ) * ( 1 - 1.000 ) \\
 &= 2.282 \text{ sq.in.}
 \end{aligned}$$

Area Available in Nozzle Projecting Outward [A2]:

$$\begin{aligned}
 &= ( 2 * tlnp ) * ( tn - trn ) * fr2 \\
 &= ( 2 * 0.955 ) * ( 0.2259 - 0.0111 ) * 1.0000 \\
 &= 0.410 \text{ sq.in.}
 \end{aligned}$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$\begin{aligned}
 &= Wo^s * fr2 + ( Wi - can / 0.707 )^s * fr2 \\
 &= 0.3750^s * 1.0000 + ( 0.0000 )^s * 1.0000 \\
 &= 0.141 \text{ sq.in.}
 \end{aligned}$$

Area Available in the Hub Section [A6]:

$$\begin{aligned}
 &= ( 2 * \min(Tlnp, ho, Hubht) ) * ( Hubtk - tn ) * fr2 \\
 &= ( 2 * \min(0.955, 6.000, 2.000) ) * ( 0.5000 - 0.3440 ) * 1.000 ) \\
 &= 0.298 \text{ sq.in.}
 \end{aligned}$$

- **Nozzle M1**

Area Required [A]:

$$\begin{aligned}
 &= 0.5( d * tr * F + 2 * tn * tr * F * (1 - fr1) ) \text{ per UG-37(d) or UG-39} \\
 &= 0.5(1.9232 * 0.2733 * 1 + 2 * 0.3819 * 0.2733 * 1 * (1 - 1.00)) \\
 &= 2.063 \text{ sq.in.}
 \end{aligned}$$

Note: The required area has been increased by the tapped hole area loss.

**Reinforcement Areas per Figure UG-37.1**

Area Available in Shell [A1]:

$$\begin{aligned}
 &= d( E1 * t - F * tr ) - 2 * tn( E1 * t - F * tr ) * ( 1 - fr1 ) \\
 &= 2.890 ( 1.00 * 1.0630 - 1.0 * 0.273 ) - 2 * 0.382 \\
 &\quad ( 1.00 * 1.0630 - 1.0 * 0.2733 ) * ( 1 - 1.000 ) \\
 &= 2.282 \text{ sq.in.}
 \end{aligned}$$

Area Available in Nozzle Projecting Outward [A2]:

$$\begin{aligned}
 &= ( 2 * tlnp ) * ( tn - trn ) * fr2 \\
 &= ( 2 * 0.955 ) * ( 0.2259 - 0.0111 ) * 1.0000 \\
 &= 0.410 \text{ sq.in.}
 \end{aligned}$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$\begin{aligned}
 &= Wo^2 * fr2 + ( Wi - can / 0.707 )^2 * fr2 \\
 &= 0.3750^2 * 1.0000 + ( 0.0000 )^2 * 1.0000 \\
 &= 0.141 \text{ sq.in.}
 \end{aligned}$$

Area Available in the Hub Section [A6]:

$$\begin{aligned}
 &= ( 2 * \min(Tlnp, ho, Hubht) ) * ( Hubtk - tn ) * fr2 \\
 &= ( 2 * \min(0.955, 6.000, 2.000) ) * ( 0.5000 - 0.3440 ) * 1.000 ) \\
 &= 0.298 \text{ sq.in.}
 \end{aligned}$$

## Lampiran 16. Tegangan Izin Material

- SA 516 Gr.60

Table A-1

ASME B31.3-1999 Edition

**TABLE A-1 (CONT'D)**  
**BASIC ALLOWABLE STRESSES IN TENSION FOR METALS<sup>1</sup>**  
Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Material	Spec. No.	P-No. or S-No. (5)	Grade	Notes	Min. Temp., °F (6)	Specified Min. Strength, ksi		Min. Temp. to 100 200 300		
						Tensile	Yield			
<b>Carbon Steel (Cont'd)</b>										
<b>Plates and Sheets</b>										
...	A 285	1	A	(57)(59)	B	45	24	15.0	14.6	14.2
...	A 285	1	B	(57)(59)	B	50	27	16.7	16.4	16.0
...	A 516	1	55	(57)	C	55	30	18.3	18.3	17.7
...	A 285	1	C	(57)(59)	A	55	30	18.3	18.3	17.7
...	A 516	1	60	(57)	C	60	32	20.0	19.5	18.9
...	A 515	1	60	(57)	B	60	32	20.0	19.5	18.9
...	A 516	1	65	(57)	B	65	35	21.7	21.3	20.7
...	A 515	1	65	(57)	A	65	35	21.7	21.3	20.7
...	A 516	1	70	(57)	B	70	38	23.3	23.1	22.5
...	A 515	1	70	(57)	A	70	38	23.3	23.1	22.5
(≤ 2½ in. thick)	A 537	1	Cl. 1	...	D	70	50	23.3	23.3	22.9
(> 1 in. thick)	A 299	1	...	(57)	A	75	40	25.0	24.4	23.7
(≤ 1 in. thick)	A 299	1	...	(57)	A	75	42	25.0	25.0	24.8

**BASIC ALLOWABLE STRESSES IN TENSION FOR METALS<sup>1</sup>**  
Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Material	Spec. No.	P-No. or S-No. (5)	Grade	Notes	Min. Temp., °F (6)	Specified Min. Strength, ksi		Min. Temp. to 100 200 300		
						Tensile	Yield			
<b>Carbon Steel</b>										
<b>Pipes and Tubes (2)</b>										
A 285 Gr. A	A 134	1	...	(8b)(57)	B	45	24	15.0	14.6	14.2
A 285 Gr. A	A 672	1	A45	(57)(59)(67)	B	45	24	15.0	14.6	14.2
Butt weld	API 5L	S-1	A25	(8a)	-20	45	25	15.0	15.0	14.5
Smls & ERW	API 5L	S-1	A25	(57)(59)	B	45	25	15.0	15.0	14.5
...	A 179	1	...	(57)(59)	-20	47	26	15.7	15.0	14.2
Type F	A 53	1	Gr. A	(8a)(77)	20	48	30	16.0	16.0	16.0
...	A 139	S-1	A	(8b)(77)	A	48	30	16.0	16.0	16.0
...	A 587	1	...	(57)(59)	-20	48	30	16.0	16.0	16.0
...	A 53	1	A	(57)(59)	B	48	30	16.0	16.0	16.0
...	A 106	1	A	(57)						
...	A 135	1	A	(57)(59)						
...	A 369	1	FPA	(57)						
...	API 5L	S-1	A	(57)(59)(77)						
A 285 Gr. B	A 134	1	...	(8b)(57)	B	50	27	16.7	16.4	16.0
A 285 Gr. B	A 672	1	A50	(57)(59)(67)	B	50	27	16.7	16.4	16.0
A 285 Gr. C	A 134	1	...	(8b)(57)	A	55	30	18.3	18.3	17.7
...	A 524	1	Gr. II	(57)	-20	55	30	18.3	18.3	17.7
...	A 333	1	1	(57)(59)	-50	55	30	18.3	18.3	17.7
...	A 334	1	1							
...	A 334	1	1							
A 285 Gr. C	A 671	1	CA55	(59)(67)	A	55	30	18.3	18.3	17.7
A 285 Gr. C	A 672	1	A55	(57)(59)(67)	A					
A 516 Gr. 55	A 672	1	C55	(57)(67)	C					
A 516 Gr. 60	A 671	1	CC60	(57)(67)	C	60	32	20.0	19.5	18.9
A 516 Gr. 60	A 671	1	CC60	(57)(67)	B	60	32	20.0	19.5	18.9
A 516 Gr. 60	A 672	1	C60	(57)(67)	B	60	32	20.0	19.5	18.9
A 516 Gr. 60	A 672	1	C60	(57)(67)	C	60	32	20.0	19.5	18.9

- SA105

**TABLE 2-1.1 RATINGS FOR GROUP 1.1 MATERIALS**

Nominal Designation	Forgings	Castings	Plates
C-Si	A 105 (1)	A 216 Gr. WCB (1)	A 515 Gr. 70 (1)
C-Mn-Si	A 350 Gr. LF2 (1)		A 516 Gr. 70 (1)(2) A 537 Cl. 1 (3)

**NOTES:**

- (1) Upon prolonged exposure to temperatures above 800°F, the carbide phase of steel may be converted to graphite. Permissible, but not recommended for prolonged use above 800°F.
- (2) Not to be used over 850°F.
- (3) Not to be used over 700°F.

**WORKING PRESSURES BY CLASSES, psig**

Class Temp., °F	150	300	400	600	900	1500	2500
-20 to 100	285	740	990	1480	2220	3705	6170
200	260	675	900	1350	2025	3375	5625
300	230	655	875	1315	1970	3280	5470
400	200	635	845	1270	1900	3170	5280
500	170	600	800	1200	1795	2995	4990
600	140	550	730	1095	1640	2735	4580
650	125	535	715	1075	1610	2685	4475
700	110	535	710	1065	1600	2665	4440
750	95	505	670	1010	1510	2520	4200
800	80	410	550	825	1235	2060	3430
850	65	270	355	535	805	1340	2230
900	50	170	230	345	515	860	1430
950	35	105	140	205	310	515	860
1000	20	50	70	105	155	260	430

Lampiran 17. *Seismic Zone*

