

DAFTAR PUSTAKA

- Depdiknas. 2013. *Gardu Induk Semester III*. Jakarta: Depdiknas.
- Mohan, Ned. 2012. *Electric Power System*. USA: Hamilton Printing.
- Marsudi, Djiteng. 2006. *Operasi Sistem Tenaga Listrik*. Yogyakarta: Graha Ilmu.
- Zuhal. 1991. *Dasar Tenaga Listrik*. Cetakan Kedua. Bandung: ITB.
- Santoso, Singgih. 2015. *Menguasai SPSS 22*. Jakarta: PT Elex Media Komputindo.
- Sulasno. 2009. *Teknik Konversi Energi Listrik dan Sistem Pengaturan*. Edisi Pertama. Yogyakarta: Graha Ilmu.
- Gross, Charles A. 1986. *Power System Analysis*. Canada: United States of America.
- Siang, Jang Jek. 2009. *Jaringan Syaraf Tiruan dan Pemrogramannya*. Edisi Kedua. Yogyakarta: ANDI
- Syahputra, R., (2016), “*Transmisi dan Distribusi Tenaga Listrik*”, LP3M UMY, Yogyakarta, 2016.
- Syahputra, R., (2015), “*Teknologi dan Aplikasi Elektromagnetik*”, LP3M UMY, Yogyakarta, 2016.
- Syahputra, R., Robandi, I., Ashari, M. (2015). Performance Improvement of Radial Distribution Network with Distributed Generation Integration Using Extended Particle Swarm Optimization Algorithm. *International Review of Electrical Engineering (IREE)*, 10(2). pp. 293-304.
- Syahputra, R., Robandi, I., Ashari, M. (2015). Reconfiguration of Distribution Network with DER Integration Using PSO Algorithm. *TELKOMNIKA*, 13(3). pp. 759-766.

- Syahputra, R., Robandi, I., Ashari, M. (2015). PSO Based Multi-objective Optimization for Reconfiguration of Radial Distribution Network. *International Journal of Applied Engineering Research (IJAER)*, 10(6), pp. 14573-14586.
- Syahputra, R. (2015). Simulasi Pengendalian Temperatur Pada Heat Exchanger Menggunakan Teknik Neuro-Fuzzy Adaptif. *Jurnal Teknologi*, 8(2), pp. 161-168.
- Syahputra, R. (2015). Characteristic Test of Current Transformer Based EMTP Shoftware. *Jurnal Teknik Elektro*, 1(1), pp. 11-15.
- Syahputra, R., (2012), “*Distributed Generation: State of the Arts dalam Penyediaan Energi Listrik*”, LP3M UMY, Yogyakarta, 2012.
- Syahputra, R., Robandi, I., Ashari, M. (2014). Optimization of Distribution Network Configuration with Integration of Distributed Energy Resources Using Extended Fuzzy Multi-objective Method. *International Review of Electrical Engineering (IREE)*, 9(3), pp. 629-639.
- Syahputra, R., Robandi, I., Ashari, M. (2014). Performance Analysis of Wind Turbine as a Distributed Generation Unit in Distribution System. *International Journal of Computer Science & Information Technology (IJCSIT)*, Vol. 6, No. 3, pp. 39-56.
- Syahputra, R., Robandi, I., Ashari, M., (2014), “Distribution Network Efficiency Improvement Based on Fuzzy Multi-objective Method”. *IPTEK Journal of Proceedings Series*. 2014; 1(1): pp. 224-229.
- Syahputra, R., (2013), “A Neuro-Fuzzy Approach For the Fault Location Estimation of Unsynchronized Two-Terminal Transmission Lines”, *International*

Journal of Computer Science & Information Technology (IJCSIT), Vol. 5, No. 1, pp. 23-37.

Syahputra, R., (2012), “Fuzzy Multi-Objective Approach for the Improvement of Distribution Network Efficiency by Considering DG”, *International Journal of Computer Science & Information Technology (IJCSIT)*, Vol. 4, No. 2, pp. 57-68.

Syahputra, R., (2010), “Aplikasi Deteksi Tepi Citra Termografi untuk Pendeteksian Keretakan Permukaan Material”, *Forum Teknik*, Vol. 33, 2010.

Syahputra, R., Soesanti, I. (2015). “Control of Synchronous Generator in Wind Power Systems Using Neuro-Fuzzy Approach”, *Proceeding of International Conference on Vocational Education and Electrical Engineering (ICVEE) 2015*, UNESA Surabaya, pp. 187-193.

Syahputra, R., Robandi, I., Ashari, M. (2014). “Optimal Distribution Network Reconfiguration with Penetration of Distributed Energy Resources”, *Proceeding of 2014 1st International Conference on Information Technology, Computer, and Electrical Engineering (ICITACEE) 2014*, UNDIP Semarang, pp. 388 - 393.

Syahputra, R., Robandi, I., Ashari, M., (2013), “Distribution Network Efficiency Improvement Based on Fuzzy Multi-objective Method”. *International Seminar on Applied Technology, Science and Arts (APTECS)*. 2013; pp. 224-229.

Syahputra, R., Robandi, I., Ashari, M., (2012), “Reconfiguration of Distribution Network with DG Using Fuzzy Multi-objective Method”, *International Conference on Innovation, Management and Technology Research (ICIMTR)*, May 21-22, 2012, Melacca, Malaysia.

- Syahputra, R. (2010). Fault Distance Estimation of Two-Terminal Transmission Lines. Proceedings of International Seminar on Applied Technology, Science, and Arts (2nd APTECS), Surabaya, 21-22 Dec. 2010, pp. 419-423.
- Syahputra, R., (2014), “Estimasi Lokasi Gangguan Hubung Singkat pada Saluran Transmisi Tenaga Listrik”, *Jurnal Ilmiah Semesta Teknik* Vol. 17, No. 2, pp. 106-115, Nov 2014.
- Syahputra, R., Robandi, I., Ashari, M., (2011), “Modeling and Simulation of Wind Energy Conversion System in Distributed Generation Units”. *International Seminar on Applied Technology, Science and Arts (APTECS)*. 2011; pp. 290-296.
- Syahputra, R., Robandi, I., Ashari, M., (2011), “Control of Doubly-Fed Induction Generator in Distributed Generation Units Using Adaptive Neuro-Fuzzy Approach”. *International Seminar on Applied Technology, Science and Arts (APTECS)*. 2011; pp. 493-501.
- Syahputra, R., Soesanti, I. (2015). Power System Stabilizer model based on Fuzzy-PSO for improving power system stability. *2015 International Conference on Advanced Mechatronics, Intelligent Manufacture, and Industrial Automation (ICAMIMIA)*, Surabaya, 15-17 Oct. 2015 pp. 121 - 126.
- Syahputra, R., Soesanti, I. (2016). Power System Stabilizer Model Using Artificial Immune System for Power System Controlling. *International Journal of Applied Engineering Research (IJAER)*, 11(18), pp. 9269-9278.
- Syahputra, R., Soesanti, I. (2016). Application of Green Energy for Batik Production Process. *Journal of Theoretical and Applied Information Technology (JATIT)*, 91(2), pp. 249-256.

- Jamal, A., Syahputra, R. (2016). Heat Exchanger Control Based on Artificial Intelligence Approach. *International Journal of Applied Engineering Research (IJAER)*, 11(16), pp. 9063-9069.
- Andrianto, Donny Swastika. 2017. *Evaluasi Kemampuan Transformator Tenaga Gardu Induk 150 kV Purworejo*. Tugas Akhir. Tidak diterbitkan. Fakultas Teknik Universitas Muhammadiyah Yogyakarta : Yogyakarta.
- Cahyadi, Qari Walu. 2017. *Evaluasi Kemampuan Transformator Tenaga Pada Gardu Induk Kentungan 150 kV*. Tugas Akhir. Tidak diterbitkan Fakultas Teknik Universitas Muhammadiyah Yogyakarta : Yogyakarta.
- Muzakka, Rihan. 2017. *Perhitungan Proyeksi Beban Transformator Dalam Perencanaan Kapasitas Gardu Induk di Yogyakarta*. Tugas Akhir. Tidak diterbitkan. Fakultas Teknik Universitas Muhammadiyah Yogyakarta : Yogyakarta
- Solikhan, Umar. 2013. “Bahasa Indonesia dalam Informasi dan Iklan di Ruang Publik Kota Pangkalpinang” dalam *Sirok Bastra: Jurnal Kebahasaan dan Kesastraan Volume 1* (hlm. 123-129). Pangkalpinang: Kantor Bahasa Provinsi Bangka Belitung Kementerian Pendidikan dan Kebudayaan.
- Zainuddin, M., Wiraputra, L. 2016. “Gardu Induk Anggrek dan Rekonfigurasi Jaringan terhadap Kualitas Tegangan dan Rugi-rugi Daya (Studi Kasus PLN Rayon Kwandang Area Gorontalo)” *Jurnal Rekayasa ElektriKa Volume 12* (hlm. 73-118). Banda Aceh


LAMPIRAN

1. Data Beban Puncak 2014-2017


- Januari 2014

 PT PLN (PERSERO) PENYALURAN DAN PUSAT PENGATUR BEBAN SUMATERA UPT TANJUNG KARANG										
Laporan Beban Tertinggi Trafo Gardu Induk										
Bulan Januari 2014										
NO	Gardu Induk	Transformator Terpasang				Beban Tertinggi				
		NO	KV	MV	K	TGL	JAM	AMP	KV	MW
1	Tegineneng	TD2	150/20		3	19:00	302	20	10	
		TD4	150/20	60 Unindo	15	20:30	278	20	8,34	

- Februari 2014

 PT PLN (PERSERO) PENYALURAN DAN PUSAT PENGATUR BEBAN SUMATERA UPT TANJUNG KARANG										
Laporan Beban Tertinggi Trafo Gardu Induk										
Bulan Februari 2014										
NO	Gardu Induk	Transformator Terpasang				Beban Tertinggi				
		NO	KV	MVA	MERK	TGL	JAM	AMP	KV	MW
1	Tegineneng	TD2	150/20	30	Unindo	18	19:30	372	20	12
		TD4	150/20	60	Unindo	19	20:00	278	20	8,34

- Maret 2014

 PT PLN (PERSERO) PENYALURAN DAN PUSAT PENGATUR BEBAN SUMATERA UPT TANJUNG KARANG										
Laporan Beban Tertinggi Trafo Gardu Induk										
Bulan Maret 2014										
NO	Gardu Induk	Transformator Terpasang				Beban Tertinggi				
		NO	KV	MVA	MERK	TGL	JAM	AMP	KV	MW
1	Tegineneng	TD2	150/20	30	Unindo	3	21:00	288	20	9
		TD4	150/20	60	Unindo	23	19:00	278	20	8,34